

GOVERNMENT OF MANIPUR
PUBLIC HEALTH ENGINEERING DEPARTMENT



No. EE/IW-PHED/TR/2025-26/ 429

Date 21/04/2025

To,
The Asst. Administrative Officer,
Ramakrishna Mission School,
Bachaspati Leikai Uripok, Imphal West

Subject: Request to issue Water Testing Certificate for "Ramakrishna Mission School"

Dear Sir,


Please find herewith the enclosed water testing report/certificate in the prescribed format for the sample collected from the Ramakrishna Mission School, Imphal, Manipur for further necessary action.

Encl:
1. Lab Testing Report.

Copy to:
1. The Assitant Engineer Concerned
2. File concerned

L. Rohan Singh
Executive Engineer,
Imphal West PHE Division,
PHED, Manipur
Executive Engineer
Imphal West P.H.E. Division
P.H.E.D. Manipur

Satani Armaileasane
Principal
Ramakrishna Mission School
Uripok, Imphal, Manipur-795001



DISTRICT LAB IMPHAL WEST PHED, GOVT. OF MANIPUR

FF-13
DLIW/PHED, Manipur
Page No. 1/1

Lamphelpat-795005 Email: dliwphed@gmail.com Name and Address/Division of Customer: Bimal Thongam Asst. Administrative Officer Ramakrishna Mission School Uripok Bachaspati Leikai, Imphal West		TEST REPORT Report No. DLIW/PHED/2025/TC1371425000000238P Date of Report: 21/8/2025 Sample ID: / 28 Date of Collection of Sample: 21/8/2025 Duration of Performance: 21/8/2025 Ref. No. Nil Date of Issue: 22/8/2025	
1	Description of Sample (As declared by customer)	Water	
2	Sample Mark (if any, given by the customer)	NA	
3	Date of Sampling by the Customer	/ /	
4	Source & Place of Sampling	1) Treated/ Water	
5	Environmental conditions during sampling	NA	
6	Sampling Plan & Procedures used	NA	
7	Quantity of Water	1 liter in Plastic Jerrican bottle	
We hereby certify that the following sample submitted to the laboratory has been analyzed with the following results			

Analysis Results (As per IS10500:2012)

Chemical Testing

Sl. No.	Characteristic	Acceptable Limit	Permissible Limit	Method of Test	Results		
						N/A	N/A
1	Iron (as Fe) in mg/l	1.0	No Relaxation	APHA 23 rd Edition 3500-Fe B	0.21		
2	Fluoride in mg/l as F	1.0	1.5	APHA 23 rd Edition 4500-F D	0.50		
3	Sulphate (as SO ₄) in mg/l	200	400	APHA 23 rd Edition 4500-SO ₄ ²⁻ E	23.00		
4	Bacteriology(A/P)	--	--	--	--		

- The results relate only to the item(s) tested.
- This Test Report shall not be reproduced except in full, without the permission of District lab. Imphal West PHED, Manipur. The reserved part of sample(s) shall be retained for 7days from the date of Completion of Test.
- Test Performed at 25 ± 2° C temp. and 50 ± 10% Relative Humidity.

Prepared by: - H. Bidyarani Devi

Signature:
Designation: Jr. Chemist

L. Roshan Singh
L. Roshan Singh
Executive Engineer
Imphal West PHE Division
PHED, Manipur

Swami Anugulakawati
Principal
Ramakrishna Mission School
Uripok, Imphal, Manipur-795001



DISTRICT LAB IMPHAL WEST PHED, GOVT. OF MANIPUR

FF-13
DLIW/PHED, Manipur
Page No. 1/1

TEST REPORT
Report No. DLIW/PHED/2025/TC1371425000000238P
Date of Report: 29/08/2025
Sample ID: / 28
Date of Collection of Sample: 29/8/2025
Duration of Performance: 29/8/2025
Ref. No. Nil
Date of Issue: 29/08/2025



TC-13714

Table with 2 columns: Description of Sample (As declared by customer) and Water. Rows include Sample Mark, Date of Sampling, Source & Place of Sampling, Environmental conditions, Sampling Plan, and Quantity of Water.

We hereby certify that the following sample submitted to the laboratory has been analyzed with the following results

Analysis Results (As per IS10500:2012)

Chemical Testing

Table with 6 columns: Sl. No., Characteristic, Acceptable Limit, Permissible Limit, Method of Test, Results. Rows include Chloride, Total Dissolved Solids, Total Alkalinity, Calcium, Magnesium, pH value, Turbidity, Total Hardness, and Electrical Conductivity.

- 1. The results relate only to the item(s) tested.
2. This Test Report shall not be reproduced except in full, without the permission of District lab. Imphal West PHED, Manipur.
3. Test Performed at 25 ± 2° C temp. and 50 ± 10% Relative Humidity.

Prepared by: - H. Bidyarani Devi
Signature:
Designation: Jr. Chemist

L. Roshan Singh
Executive Engineer
Imphal West PHE Division
PHED, Manipur

Suman Atmakusand
Principal
Ramakrishna Mission School
Uripok, Imphal, Manipur-795001